

**ADDENDUM 001**

**Request for Bid: D1-10-084**

The due date for receipt of bids remains unchanged by this Addendum. Accordingly, the following changes, questions and answers are believed to be of general interest to all potential Offerors. The original solicitation is hereby changed to the extent stated in the department's response to each question on the attached pages of this amendment 001. All other terms and conditions remain unchanged and in full force.

Please sign and return with your bid.

Name and Title of Signer (Print or type)	Name and Title of Department Authority  Darrel Butcher, CPPB Senior Procurement Agent
Contractor/Offeror Signature  <hr/> (Signature of person authorized to sign)	Department of Transportation  <i>Darrel Butcher, CPPB</i> (Authorizing Signature)
Date Signed:	Date Signed: 09/30/09

**Addition:**

1. Only the vertical door framing members will be replaced with 2 X 10 treated wood.
2. Only the east 7 doors are to be removed.
3. MoDOT will take lose from the door framing any air lines, electrical conduits, tools, hangers, as well as anything else that might impede the installation of garage doors and new frame.
4. Liability insurance is \$500,000 per each individual per accident or occurrence and \$1,000,000 each accident or occurrence.
5. Materials used will be two piece solid steel shafts, springs rated at 25,000 cycles, doors to be white color inside and out, and stainless steel lift cables shall have a safety factor of 8 to 1.

